

**2010 CONSUMER CONFIDENCE REPORT**  
**Hillsdale Housing Cooperative Corporation, Inc.**  
**West Kingston, RI**  
**PWS ID#2942525**

We are very pleased to provide you with this year's Consumer Confidence Report. This report provides you with information on the water and services that we delivered to you in 2010. Included are details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies.

We want our valued customers to be informed about their water utility. If after reviewing this report you have any questions, or would like to know more about Hillsdale Housing Cooperative Corporation, Inc. water system, please call Maria Tavares at (401) 539-2334. Our Board of Directors meetings are held the third Monday of each month. You are also invited to attend our annual meeting which is held on the third Wednesday of October each year.

**The Quality of Your Drinking Water**

Our goal is to provide you with a safe and dependable supply of drinking water. However, in 2010, testing showed the running annual average for Combined Radium and Beryllium above the EPA standard. Additionally, we failed to take required lead and copper samples in 2010. Please see the drinking water 2010 Test Results Table on page two and Violations section on page three for additional details. We are committed to ensuring the quality of your water.

**The Source of Your Drinking Water**

Our water source is two wells located on the premises. They are both rock wells, five hundred and fifty-feet deep, and they provide 97 gallons of water per minute.

The RI Department of Health, in cooperation with other state and federal agencies, has assessed the threats to the Hillsdale Housing Cooperative Corporation's water supply sources. The assessment considered the intensity of development, the presence of businesses and facilities that use, store or generate potential contaminants, how easily contaminants may move through the soils in the Source Water Protection Area (SWPA), and the sampling history of the water.

Our monitoring program continues to assure that the water delivered to your home is safe to drink. However, the assessment found that the water source is at LOW RISK of contamination. This does NOT mean that the water cannot become contaminated. Protection efforts are necessary to assure continued water quality. The complete Source Water Assessment Report is available from the Hillsdale Housing Cooperative Corporation or the Department of Health at (401) 222-6867.

**Why Are There Contaminants in My Drinking Water?**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity:

- **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- **Inorganic contaminants**, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- **Radioactive contaminants**, which can be naturally occurring or the result of oil and gas production and mining activities.

## Water Quality Test Results

The table below lists all of the drinking water contaminants that were detected through our water quality monitoring and testing. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from the January – December 2010 monitoring period. For those contaminants that are monitored less frequently the most recent test results are listed.

Maximum Contaminant Levels (MCL's) are set at very stringent levels. The Maximum Contaminant Level Goal (MCLG) is set at a level where no health effects would be expected, and the MCL is set as close to that as possible, considering available technology and cost of treatment. A person would have to drink 2 liters of water every day, as recommended by health professionals, at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

2010 TEST RESULTS							
Radioactive Contaminants	Violation Y/N	Level Detected		Unit Measurement	MCLG	MCL	Likely Source of Contamination
		Well #1A	Well #2				
Gross Alpha (2009)	N	12.97	5.05	pCi/L	0	15	Erosion of natural deposits
Combined Radium*	N	4.73-13.93	1.00 -1.96	pCi/L	0	5	Erosion of natural deposits
Inorganic Contaminants	Violation Y/N	Level Detected		Unit Measurement	MCLG	MCL	Likely Source of Contamination
		Well #1A	Well #2				
Barium (2009)	N	0.05	0.03	ppm	2	2	Discharge of drilling waste; discharge from metal refineries; erosion of natural deposits
Beryllium*	Y	RAA 12 Range 1-21	1 (2009)	ppb	4	4	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries.
*The level presented is the highest Running Annual Average (RAA) from 2010. The RAA is the average of consecutive quarters of testing. Please note, we mix the water from Well #1A and Well #2 before distribution to you our customers. Testing done at the distribution system showed no detectable levels of Beryllium.							
Chromium (2009)	N	2	2	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
Fluoride (2009)	N	1.48	1.50	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.
DISTRIBUTION TEST RESULTS							
Radioactive Contaminants	Violation Y/N	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination	
Gross Alpha (2009)	N	6.67	pCi/L	0	15	Erosion of natural deposits	
Combined Radium	Y	2.45 - 5.89	pCi/L	0	5	Erosion of natural deposits	
Inorganic Contaminants	Violation Y/N	Level Detected 90 <sup>th</sup> Percentile	Unit Measurement	MCLG	MCL	Likely Source of Contamination	
Copper (2007)	N	0.01	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives	
Lead (2007)	N	1	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits	

**Action Level (AL)** - The concentration of a contaminant which if exceeded, triggers treatment or other requirements which a water system must follow.

**Parts per million (ppm) or Milligrams per liter (mg/L)** - One part per million corresponds to one minute in two years or a single penny in \$10,000.

**Parts per billion (ppb) or Micrograms per liter (ug/L)** - One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

**Picocuries per liter (pCi/L)** - Picocuries per liter is a measure of the radioactivity in water.

**Maximum Contaminant Level (MCL)** -The MCL is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - The MCLG is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

For most people, the health benefits of drinking plenty of water outweigh any possible health risk from these contaminants. However, some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have

undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Hillsdale Housing Cooperative Corporation is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

#### **Violations:**

**Copper & Lead Monitoring Violation:** In 2010, we were required to sample for lead and copper test. We failed to take these samples. We will be sampling in 2011 to correct this oversight.

**Copper:** Copper is an essential nutrient; some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water contain copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.

**Lead:** Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficiencies in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure. Lead in drinking water is rarely the sole cause of lead poisoning, but it can add to a person's total lead exposure. All potential sources of lead in the household should be identified and removed, replaced or reduced.

**Beryllium MCL Violation:** In 2010, our second quarter running annual average (RAA) exceeded the standard, or maximum contaminant level (MCL), for beryllium. HCC has submitted an Engineering Evaluation Report to HEALTH that presents specific recommendations regarding modifications to the water supply wells, provision of treatment and upgrades to the distribution system and implementation cost estimates. In addition to beryllium, the recommended corrective action plan also provides a positive resolution of the radium, pH, iron and manganese contamination problems. HHC is presently working to obtain the funding to execute the recommendations presented in the Engineering Evaluation Report.

**Beryllium:** Some people who drink water containing beryllium well in excess of the MCL over many years could develop intestinal lesions.

**Combined Radium MCL Violation:** In 2010, we exceeded the maximum contaminant level (MCL), for combined radium. Our test results ranged from 2.45 - 5.89 pCi/L, the MCL is 5 pCi/L. We will be installing a treatment system to resolve this issue. We're working on procuring funding to finance the upgrade.

**Combined Radium:** Some people who drink water containing radium 226 or 228 in excess of the MCL over many years may have an increased risk of getting cancer.

We at the Hillsdale Housing Cooperative Corporation work to provide top quality water to every tap. We encourage all of our customers to conserve and use water efficiently and remind you to help us protect our water sources, which are the heart of our community, our way of life and our children's future. Please do not hesitate to call our office with any questions.