

2010 CONSUMER CONFIDENCE REPORT

North Tiverton Fire District

North Tiverton, RI

PWS ID#1592018

We are very pleased to provide you with this year's Consumer Confidence Report. This report provides you with information on the water and services that we delivered to you in 2010. Included are details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies.

We want our valued customers to be informed about their water utility. If after reviewing this report you have any questions, or would like to know more about the North Tiverton Fire District water system, please call the Superintendent at 401-624-8432. The District's offices are located at 241 Hilton Street in North Tiverton, RI. Office hours are 8:45 AM – 12:00 Noon and 1:00 PM to 4:15 PM during normal business days.

The Quality of Your Drinking Water

The quality of your drinking water is excellent and your water is safe to drink. The North Tiverton Fire District and all of its employees are committed to providing you with a safe and dependable supply of drinking water. We're proud to inform you that your drinking water meets all Federal and State requirements. We are committed to ensuring the quality of your water.

The Source of Your Drinking Water

We purchase our water from two separate sources, the City of Fall River, Massachusetts from the north, and the Stone Bridge Fire District from the south. We receive approximately 50% of our water from the City of Fall River and 50% from the Stone Bridge Fire District. The water that the District receives from Fall River comes from the Wattupa Water Board's surface reservoirs. The Wattupa reservoir complex is located in a basin area totaling more than 1,700 acres of which 90% is forested land. When full, the reservoir system contain more than nine (9) billion gallons of water. Before delivery to the transmission and distribution system, all water from the reservoir system is treated at the North Wattupa Water Treatment plant. The Stone Bridge Fire District obtains its water from Stafford Pond in Tiverton, RI. Before delivery to the transmission and distribution system all water from the reservoir system is treated at the Stone Bridge Fire District Water Treatment Plant which is located on the west side of Stafford Pond.

The drinking water from both of these sources is delivered to the homes and businesses in North Tiverton through a transmission and distribution system that includes two (2) pumping stations with treatment systems, two (2) storage tanks, and 32 miles of pipe which include valves for control of water flow. Water connections to each building include a connection to main pipe, a valve on the connecting pipe and a water meter to measure water use. Water is also available for fire fighting through direct connection to 184 public fire hydrants.

The RI Department of Health, in cooperation with other state and federal agencies, has assessed the threats to Stone Bridge Fire District water supply sources. The assessment considered the intensity of development, the presence of businesses and facilities that use, store or generate potential contaminants, how easily contaminants may move through the soils in the Source Water Protection Area (SWPA), and the sampling history of the water.

Our monitoring program continues to assure that the water delivered to your home is safe to drink. However, the assessment found that the water source is at MODERATE RISK of contamination. This means the water could one day become contaminated. Monitoring and protection efforts are necessary to assure continued water quality. The complete Source Water Assessment Report is available from Stone Bridge Fire District or the Department of Health at (401) 222-6867.

Why Are There Contaminants in My Drinking Water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity:

- **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- **Inorganic contaminants**, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- **Radioactive contaminants**, which can be naturally occurring or the result of oil and gas production and mining activities.

Water Quality Test Results

The table below lists all of the drinking water contaminants that were detected through our water quality monitoring and testing. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from the January – December 2010 monitoring period. For those contaminants that are monitored less frequently the most recent test results are listed.

Maximum Contaminant Levels (MCL's) are set at very stringent levels. The Maximum Contaminant Level Goal (MCLG) is set at a level where no health effects would be expected, and the MCL is set as close to that as possible, considering available technology and cost of treatment. A person would have to drink 2 liters of water every day, as recommended by health professionals, at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

2010 TEST RESULTS FROM STONE BRIDGE FIRE DISTRICT & FALL RIVER							
Radioactive Contaminants	Violation Y/N	Level Detected		Unit Measurement	MCLG	MCL	Likely Source of Contamination
		Stone Bridge	Fall River				
Combined Radium	N	1.70 (2008)	*	pCi/L	0	5	Erosion of natural deposits

*Data last tested in 2004, no longer needs to be reported.

Microbiological Contaminants	Violation Y/N	Level Detected		Unit Measurement	MCLG	MCL	Likely Source of Contamination
		Stone Bridge	Fall River				
Total Organic Carbon (TOC) ¹	N	Average 1.70 Range: 1.00 – 2.80	2.20	ppm	N/A	TT	Naturally present in the environment
Turbidity ²	N	0.21	0.08	NTU	NA	TT	Soil runoff

¹Annual average. In order to comply with the EPA standard, the TOC removal ratio must be greater than 1.0 ppm. Total organic carbon (TOC) has no health effects. However, total organic carbon provides a medium for the formation of disinfection byproducts like TTHMs and HAAs.

²Stone Bridge: 0.21 NTU was the highest single turbidity measurement recorded. The lowest monthly percentage of samples meeting the turbidity limit was 100%. Fall River: 0.08 was the highest single turbidity measurement recorded. Turbidity is a measure of cloudiness of the water. It is monitored because it is a good indication of water quality. Turbidity has no health effects, however, it can interfere with disinfection and provide a medium for microbial growth.

Inorganic Contaminants	Violation Y/N	Level Detected		Unit Measurement	MCLG	MCL	Likely Source of Contamination
		Stone Bridge	Fall River				
Barium	N	0.01	0.01	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Fluoride	N	ND	1.10 Range 0.90-1.10	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Volatile Organic Contaminants/ Disinfection By-Products Rule†	Violation Y/N	Level Detected		Unit Measurement	MCLG	MCL	Likely Source of Contamination
		Stone Bridge	Fall River				
Chlorine	N	Average* 1.20 Range 1.00 – 1.60	Average 1.75	ppb	MRDLG 4	MRDL 4	Water additive used to control microbes
Haloacetic Acids (HAA5)	N	Average*15 Range 14–16	Range18–20	ppb	N/A	60	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM)	N	Average*40 Range 21 – 56	Range 19–60	ppm	0	80	By-product of drinking water chlorination

† All of these results are from Stone Bridge and Fall River's distribution system. The averages presented are Running Annual Averages.

2010 TEST RESULTS FROM THE NORTH TIVERTON FIRE DISTRICT DISTRIBUTION SYSTEM							
Inorganic Contaminants	Violation Y/N	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination	
Copper (2008)	N	0.05	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives	
Fluoride ¹	N	1.17 Range 0.97–1.17	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories	
Lead (2008)	N	7	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits	

¹North Tiverton adds Fluoride to the Stone Bridge water supply as an aid in dental cavity prevention in young children.

Volatile Organic Contaminants	Violation Y/N	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Chlorine	N	Average* 1.34 Range 1.14–1.65	ppm	4	4	Water additive used to control microbes
Haloacetic Acids (HAA)	N	Average*18 Range 9–27	ppb	N/A	60	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM)	N	Average*59 Range 51–72	ppb	0	80	By-product of drinking water chlorination
*Running Annual Average						

Non Detect (ND) - Laboratory analysis indicated the contaminant was not present

Parts per million (ppm) or Milligrams per liter (mg/L) - One part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (ug/L) - One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) - Picocuries per liter is a measure of the radioactivity in water.

Action Level (AL) - The concentration of a contaminant which if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) -The MCL is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The MCLG is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfection Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Treatment Technique (TT) - A required process intended to reduce the level of a contaminant in drinking water.

Nephelometric Turbidity Unit (NTU) – Nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU's is just noticeable to the average person. Turbidity had no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth.

For most people, the health benefits of drinking plenty of water outweigh any possible health risk from these contaminants. However, some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The North Tiverton Fire District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

We at the North Tiverton Fire District work to provide top quality water to every tap. We encourage all of our customers to conserve and use water efficiently and remind you to help us protect our water sources, which are the heart of our community, our way of life and our children's future. Please do not hesitate to call our office with any questions.