

# 2016 CONSUMER CONFIDENCE REPORT

## Centre of New England - Boulevard System

Coventry, RI  
PWSID# RI2980453

We are very pleased to provide you with this year's Consumer Confidence Report. This report provides you with information on the water and services that we delivered to you in 2016. Included are details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies.

We want our valued customers to be informed about their water utility. There are no regularly scheduled meetings, therefore; if after reviewing this report you have any questions, or would like to know more about the Centre of New England - Boulevard System, please call Matt McGowan at 401-274-0300.

### The Quality of Your Drinking Water

Our goal is to provide you with a safe and dependable supply of drinking water. In 2016, we were issued a notice of violation for the failure to submit and distribute our 2015 CCR. More information is contained later in this report. We are committed to ensuring the quality of your water.

### The Source of Your Drinking Water

We purchase our water from the Kent County Water Authority.

The RI Department of Health, in cooperation with other state and federal agencies, has assessed the threats to Centre of New England – Boulevard System water supply sources. The assessment considered the intensity of development, the presence of businesses and facilities that use, store or generate potential contaminants, how easily contaminants may move through the soils in the Source Water Protection Area (SWPA), and the sampling history of the water.

Our monitoring program continues to assure that the water delivered to your home is safe to drink. The complete Source Water Assessment Report is available from Centre of New England – Boulevard System or the Department of Health at (401) 222-6867.

### Why Are There Contaminants in My Drinking Water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity:

- **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- **Inorganic contaminants**, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- **Radioactive contaminants**, which can be naturally occurring or the result of oil and gas production and mining activities.

### Water Quality Test Results

The following table lists all of the drinking water contaminants that were detected through our water quality monitoring and testing. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from the January – December 2016 monitoring period. For those contaminants that are monitored less frequently the most recent test results are listed.

Maximum Contaminant Levels (MCL's) are set at very stringent levels. The Maximum Contaminant Level Goal (MCLG) is set at a level where no health effects would be expected, and the MCL is set as close to that as possible, considering available technology and cost of treatment. A person would have to drink 2 liters of water every day, as recommended by

health professionals, at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

2016 TEST RESULTS For KENT COUNTY WATER AUTHORITY						
Microbiological Contaminants	Violation Y/N	Level Detected (Range)	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Total Coliform Bacteria (2016)	N	1% (0-1%)	Monthly Max %	0%	Presence of Coliform bacteria in >5% of monthly samples	Naturally present in the environment
Fecal Coliform and/or <i>E.coli</i> * (2016)	N	1 Sample (ND-1)	n/a	0	0	Human and animal fecal waste
Total Organic Carbon (2016)	N	1.59 (1.59-1.71)	ppm	n/a	TT	Naturally present in the environment
Turbidity (2016)	N	0.50 (0.02-0.50)	NTU	n/a	TT	Soil runoff
Inorganic Contaminants	Violation Y/N	Level Detected (Range)	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Barium (2016)	N	0.01 (N/A)	ppm	2	2	Erosion of natural deposits
Chlorine (2016)	N	RAA = 0.53 (0.31-0.74)	ppm	MRDLG = 4	MRDL = 4	Water additive used to control microbes
Chromium (2014)	N	5.0 (0.24-5.0)	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
Copper ** (2015)	N	0.013	ppm	1.3	AL=1.3	Corrosion of household plumbing systems
Lead ** (2015)	N	4.0	ppb	0	AL=15	Corrosion of household plumbing systems
Nitrate (as Nitrogen) (2016)	N	3.5 (0.22-2.92)	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; Erosion of natural deposits
Volatile Contaminants	Violation Y/N	Level Detected (Range)	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Total Haloacetic Acids (HAA5) (2016)	N	RAA** = 17 (7-23)	ppb	0	60	By-product of drinking water chlorination
Total Trihalomethanes (TTHM) (2016)	N	RAA** = 61 (23-78)	ppb	0	80	By-product of drinking water chlorination

\* *E.coli* are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely compromised immune systems.

\*\*All sampling results represented at the 90<sup>th</sup> Percentile. For Copper, 0 of 32 samples were above the action level. For Lead, 2 of 32 samples were above the action level.

\*\*RAA: Running Annual Average, is the average of all monthly or quarterly samples for the last year at all sample locations.

ND = Net Detected

2016 DISTRIBUTION SYSTEM TEST RESULTS FOR CENTRE OF NEW ENGLAND – BOULEVARD SYSTEM						
Inorganic Contaminants	Violation Y/N	Level Detected (Range)	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Chlorine (2016)	N	RAA = 0.13 (0.1-0.2)	ppm	MRDLG = 4	MRDL = 4	Water additive used to control microbes
Copper* (2016)	N	0.028 (0.0-0.038)	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead* (2016)	N	0.8 (0.0-2.6)	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

\*All sampling results represented at the 90<sup>th</sup> Percentile. All 20 Copper samples fell below the Action Level for Copper, where as Lead had 1 of 20 samples exceeding the Action Level. The resulting calculated 90<sup>th</sup> Percentile for both Lead and Copper were below their respective Action Levels.

Volatile Contaminants	Violation Y/N	Level Detected (Range)	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Total Haloacetic Acids (HAA5) (2016)	N	RAA** = 15 (10.9-18.5)	ppb	0	60	By-product of drinking water chlorination
Total Trihalomethanes (TTHM) (2016)	N	RAA** = 57.6 (40.1-71.1)	ppb	0	80	By-product of drinking water chlorination

**Parts per million (ppm) or Milligrams per liter (mg/L)** - One part per million corresponds to one minute in two years or a single penny in \$10,000.

**Parts per billion (ppb) or Micrograms per liter (ug/L)** - One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

**Picocuries per liter (pCi/L)** - Picocuries per liter is a measure of the radioactivity in water.

**Action Level (AL)** - The concentration of a contaminant which if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Contaminant Level (MCL)** -The MCL is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - The MCLG is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

## Violations

### Consumer Confidence Report Reporting Violation

Our system failed to submit our 2015 Consumer Confidence Report (CCR) to the Rhode Island Department of Health's Center for Drinking Water Quality by July 1<sup>st</sup>, 2016 as required by State and Federal regulations, and thus were issued this violation. Since this violation, the report was submitted to the Department of Health and we have been found to be in compliance and the matter closed. This does not pose a threat to the quality of our water.

For most people, the health benefits of drinking plenty of water outweigh any possible health risk from these contaminants. However, some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Rockville Mill Community Water System is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

We at Centre of New England - Boulevard System work to provide top quality water to every tap. We encourage all of our customers to conserve and use water efficiently and remind you to help us protect our water sources, which are the heart of our community, our way of life and our children's future. Please do not hesitate to call our office with any questions.