

2017 CONSUMER CONFIDENCE REPORT
Quonochontaug East Beach Water Association
Charlestown, RI
PWS ID#1647511

We are very pleased to provide you with this year's Consumer Confidence Report. This report provides you with information on the water and services that we delivered to you in 2017. Included are details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies.

We want our valued customers to be informed about their water utility. If after reviewing this report you have any questions, or would like to know more about the Quonochontaug East Beach Water Association water system, please contact Robert Pompei at 401-741-4042, or attend the annual meeting on the second Saturday in August.

The Quality of Your Drinking Water

Our goal is to provide you with a safe and dependable supply of drinking water. We are committed to ensuring the quality of your water.

The Source of Your Drinking Water

Our water source is two wells (#1 and #2) located on Sea Breeze Avenue. We treat our water with soda ash for corrosion control and with ultraviolet light for bacteria control. Although both wells are classified as "active", we only are using Well #1 to supply you all with drinking water. Well #2 is our back up well and is not used on a regular basis. In fact, we have not used Well #2 November of 2014. We are still required to test this well on a regular basis, but again, you are not consuming this water. It is only for emergency backup.

The RI Department of Health, in cooperation with other state and federal agencies, has assessed the threats to Quonochontaug East Beach Water Association's water sources. The assessment considered the intensity of development, the presence of businesses and facilities that use, store, or generate potential contaminants, how easily contaminants may move through the soils in the Source Water Protection Area (SWPA), and the sampling history of the water.

Our monitoring program continues to assure that the water delivered to your home is safe to drink. However, the assessment found that the water source is at MODERATE RISK of contamination. This means the water could one day become contaminated. Monitoring and protection efforts are necessary to assure continued water quality. The complete Source Water Assessment Report is available from the Quonochontaug East Beach Water Association or the Department of Health at (401) 222-6867.

Why Are There Contaminants in My Drinking Water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity:

- **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- **Inorganic contaminants**, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- **Radioactive contaminants**, which can be naturally occurring or the result of oil and gas production and mining activities.

Water Quality Test Results

The table below lists all of the drinking water contaminants that were detected through our water quality monitoring and

testing. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from the January – December 2017 monitoring period. For those contaminants that are monitored less frequently the most recent test results are listed.

Maximum Contaminant Levels (MCL's) are set at very stringent levels. The Maximum Contaminant Level Goal (MCLG) is set at a level where no health effects would be expected, and the MCL is set as close to that as possible, considering available technology and cost of treatment. A person would have to drink 2 liters of water every day, as recommended by health professionals, at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

2017 TEST RESULTS

Contaminants	Violation Y/N	Level Detected (Range)	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants						
Total Coliform Bacteria (November 2017)	N	Present (1 Positive)	Highest # of monthly positive samples	0	1 positive	Naturally present in the environment
Microbiological Contaminants						
Barium (2015)	N	0.039 single sample	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Chromium (2015)	N	4.0 single sample	ppb	100	100	Discharge from steel and pulp mills; Erosion of natural deposits
Copper** (2015)	N	0.735	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead** (2015)	N	1.0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Nitrate (as Nitrogen) (2017)	N	7.16 (3.8-7.16)	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; Erosion of natural deposits
Unregulated Contaminants (contaminants with a health advisory)						
Contaminant	Level Detected	Unit Measurement	Minimum Reporting Level	Likely Source of Contamination		
Perfluorooctanesulfonic Acid (PFOS) (2017)	6.29	ng/L	0.04	Surfactant or emulsifier; used in fire-fighting foam, circuit board etching acids, alkaline cleaners, floor polish, and as a pesticide active ingredient for insect bait traps. U.S. manufacture of PFOS phased out in 2002, however PFOS still generated incidentally		
Perfluorooctanoic Acid (PFOA) (2017)	8.91	ng/L	0.02	Perfluorinated aliphatic carboxylic acid; used for its emulsifier and surfactant properties in or as fluoropolymers (such as Teflon), fire-fighting foams, cleaners, cosmetics, greases and lubricants, paints, polishes, adhesives, and photographic films.		
Perfluorohexanesulfonic Acid (PFHxA) (2017)	5.16	ng/L	0.03	Manmade chemical; used in products to make them stain, grease, heat, and water resistant		
Perfluorobutanesulfonic Acid (PFBS) (2017)	5.66	ng/L	0.09	Manmade chemical; used in products to make them stain, grease, heat, and water resistant		
Perfluoropentanoic Acid (PFPEA) (2017)	4.53	ng/L	0.01	Manmade chemical; used in products to make them stain, grease, heat, and water resistant		

**All sampling results represented at the 90th Percentile

ND = Net Detected

Parts per million (ppm) or Milligrams per liter (mg/L) - One part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (ug/L) - One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) or Nanograms per liter (ng/L) - One part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000, 000.

Picocuries per liter (pCi/L) - Picocuries per liter is a measure of the radioactivity in water.

Action Level (AL) - The concentration of a contaminant which if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) -The MCL is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The MCLG is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

The State of Rhode Island requires testing for other contaminants not regulated by the US EPA. The following contaminant was detected in our well water:

Diethylphthalate: In 2015, diethylphthalate was detected in Well #2 at 3.0 ug/L.

Sodium: In 2017, Sodium was detected at 26.6 ppm

The nitrate level in both wells is elevated and has been rising over the past few years. While not yet considered a health problem by RIDOH, if the level continues to rise, QEBWA will have to implement serious and costly measures to correct the problem. Your cooperation with the water quality initiatives that QEBWA and Charlestown have initiated is very important. These include not using lawn chemicals or water of lawns, proper maintenance of septic systems, and upgrading septic systems to denitrifications systems.

PFAS Language

Our water system has sampled for a series of unregulated contaminants known as Per/polyfluorinated Alkyl Substances (PFASs). Unregulated contaminants are those that don't yet have a drinking water standard set by EPA. As our customers, you have a right to know that these data are available. If you are interested in examining the results please look at the data above, or please contact Robert Pompei at 401-741-4042 or 41 Highland Rd, Charlestown, RI 02813.

Consumer Confidence Report Reporting Violation

Our system failed to submit our 2016 Consumer Confidence Report (CCR) to the Rhode Island Department of Health's Center for Drinking Water Quality by July 1st, 2017 as required by State and Federal regulations, and thus were issued this violation. The report was submitted on March 14, 2018 to the Department of Health and we have been found to be in compliance and the matter closed. This does not pose a threat to the quality of our water.

For most people, the health benefits of drinking plenty of water outweigh any possible health risk from these contaminants. However, some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Quonochontaug East Beach Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

We at Quonochontaug East Beach Water Association work to provide top quality water to every tap. We encourage all of our customers to conserve and use water efficiently and remind you to help us protect our water sources, which are the heart of our community, our way of life and our children's future. Please do not hesitate to call our office with any questions.