

2017 CONSUMER CONFIDENCE REPORT

South Kingstown Nursing & Rehab Center

West Kingstown, RI

PWSID# RI2882117

We are very pleased to provide you with this year's Consumer Confidence Report. This report provides you with information on the water and services that we delivered to you in 2017. Included are details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies.

We want our valued customers to be informed about their water utility. There are no regularly scheduled meetings, therefore; if after reviewing this report you have any questions, or would like to know more about the South Kingstown Nursing & Rehab Center water system, please call Laura Wischnowsky at 401-783-8568.

The Quality of Your Drinking Water

Our goal is to provide you with a safe and dependable supply of drinking water. We're proud to inform you that your drinking water meets all Federal and State requirements. We are committed to ensuring the quality of your water.

The Source of Your Drinking Water

Our water source is two drilled wells, Well #2 and #3A, on the premises drawn from the Chipuxet Aquifer. Currently, only wells #2 and #3A are active, well #3 is inactive. We have an ion exchange and aeration treatment system which removes elevated levels of Uranium from our water. We will continue to do additional monitoring to assess the optimal operation of our treatment systems.

The RI Department of Health, in cooperation with other state and federal agencies, has assessed the threats to South Kingstown Nursing & Rehab Center water supply sources. The assessment considered the intensity of development, the presence of businesses and facilities that use, store or generate potential contaminants, how easily contaminants may move through the soils in the Source Water Protection Area (SWPA), and the sampling history of the water.

Our monitoring program continues to assure that the water delivered to your home is safe to drink. However, the assessment found that the water source is at LOW RISK of contamination. This does NOT mean that the water cannot become contaminated. Protection efforts are necessary to assure continued water quality. The complete Source Water Assessment Report is available from South Kingstown Nursing & Rehab Center or the Department of Health at (401) 222-6867.

Why Are There Contaminants in My Drinking Water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

In order to ensure that tap water is safe to drink, the EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity:

- **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- **Inorganic contaminants**, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- **Radioactive contaminants**, which can be naturally occurring or the result of oil and gas production and mining activities.

Water Quality Test Results

The following table lists all of the drinking water contaminants that we've detected. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from the January – December 2017 monitoring period. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

Maximum Contaminant Levels (MCL's) are set at very stringent levels. The Maximum Contaminant Level Goal (MCLG) is set at a level where no health effects would be expected, and the MCL is set as close to that as possible, considering available technology and cost of treatment. A person would have to drink 2 liters of water every day, as recommended by health professionals, at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effects.

2017 TEST RESULTS

Contaminants	Violation Y/N	Level Detected (Range: single samples)	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Microbiological Contaminants						
Turbidity (2014)	N	0.14	NTU	n/a	TT	Soil Runoff
Radioactive Contaminants						
Gross Alpha (incl. radon & uranium) (2017)	N	61.2	pCi/L	0	15	Erosion of natural deposits
Gross Beta Particle Activity (2014)	N	5.16	pCi/L	0	50	Decay of natural and man-made deposits
Combined Radium (2015)	N	1.0	pCi/L	0	5	Erosion of natural deposits
Combine Uranium (2017)	N	97	µg/L	0	30	Naturally occurring radioactivity in bedrock.
Inorganic Contaminants						
Barium (2017)	N	0.046	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Chromium (2017)	N	2.0	ppb	100	100	Discharge from steel and pulp mills; Erosion of natural deposits
Copper* (2014)	N	0.032	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead* (2014)	N	4.0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Nitrate (as Nitrogen) (2017)	N	1.16	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; Erosion of natural deposits
Nitrite (as Nitrogen) (2017)	N	1.41	ppm	1	1	Runoff from fertilizer use; leaching from septic tanks, sewage; Erosion of natural deposits

*All sampling results represented at the 90th Percentile

ND = Net Detected

Parts per million (ppm) or Milligrams per liter (mg/L) - One part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (µg/L) - One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) - Picocuries per liter is a measure of the radioactivity in water.

Action Level (AL) - The concentration of a contaminant which if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) -The MCL is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The MCLG is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

The State of Rhode Island requires testing for other contaminants not regulated by the US EPA. The following contaminant was detected in our well water:

Sodium: In 2017, Sodium was detected at 77.2 ppm.

Sodium Notification

The reason for this notification is so that consumers on low or restricted sodium diets may take into account their sodium intake from the drinking water. If you have been placed on a sodium restricted diet, please inform your physician that your water contained approximately 77.2 mg/L of sodium as a result of testing completed in 2017.

Gross Alpha Notification

In 2017, Gross Alpha test results exceeded the MCL of 15 pCi/L established by the U.S. Environmental Protection Agency (EPA) in the Radionuclides Rule. Certain minerals are radioactive and emit a form of radiation known as Alpha emitting radiation. Drinking water containing Gross Alpha above the MCL over the course of a lifetime increases the risk of getting cancer. You do not need to use an alternative (e.g. bottled water) supply, unless you wish to do so. However, if you have specific health concerns, please consult your physician prior to consuming water containing Gross Alpha emitters.

Uranium Notification

In 2017, our water system results exceeded the MCL of 30 µg/L established by the U.S. Environmental Protection Agency (EPA) in the Radionuclides Rule. Drinking water containing Uranium above the MCL over the course of a lifetime increases the risk of getting cancer and kidney toxicity.

Consumer Confidence Report Reporting Violation

Our system failed to submit our 2016 Consumer Confidence Report (CCR) to the Rhode Island Department of Health's Center for Drinking Water Quality by July 1st, 2017 as required by State and Federal regulations, and thus were issued this violation. The report was submitted on August 28, 2017 to the Department of Health and we have been found to be in compliance and the matter closed. This does not pose a threat to the quality of our water.

Lead and Copper Monitor/Reporting Violation

During the monitoring period of January 1, 2015 to December 31, 2017, our water system failed to test and report Lead & Copper results to the Rhode Island Department of Health's Center for Drinking Water Quality. The collection and testing of ten (10) samples for Lead and Copper will be completed in 2018 and the results will be made available in future reports. We will comply with the testing schedule in compliance with the Department of Health's regulations.

For most people, the health benefits of drinking plenty of water outweigh any possible health risk from these contaminants. However, some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The South Kingstown Nursing & Rehab Center is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

We at South Kingstown Nursing & Rehab Center work to provide top quality water to every tap. We encourage all of our customers to conserve and use water efficiently and remind you to help us protect our water sources, which are the heart of our community, our way of life and our children's future. Please do not hesitate to call our office with any questions.